



# TORRINGTON AREA HEALTH DISTRICT

350 Main Street ♦ Suite A ♦ Torrington, Connecticut 06790  
Phone (860) 489-0436 ♦ Fax (860) 496-8243 ♦ E-mail info@tahd.org ♦ Web www.tahd.org

*"Promoting Health & Preventing Disease Since 1967"*

Borough of Bantam

Bethlehem

August 31, 2015

Canaan

Cornwall

Kent Johnson  
233 E. Main Street  
Torrington, CT 06790

Goshen

Harwinton

Dear Mr. Johnson,

Kent

Please see the attached documents that the August 18, 2015 order refers to.

Borough of Litchfield

Thank you

Litchfield

Anastasiya Domnich-Kovalevsky, MPH

Middlebury

Morris

Norfolk

North Canaan

Plymouth

Salisbury

Thomaston

Torrington

Warren

Watertown

Winsted

The Torrington Area Health District is an equal opportunity provider, and employer.  
To file a complaint of discrimination write USDA, Director, Office of Civil Rights, 1400 Independence Avenue, S.W.,  
Washington, D.C., 20250-9410, or call (800) 795-3272 (voice), or (202) 720-6382 (TDD).



# TORRINGTON AREA HEALTH DISTRICT

350 Main Street ♦ Suite A ♦ Torrington, Connecticut 06790  
Phone (860) 489-0436 ♦ Fax (860) 496-8243 ♦ E-mail info@tahd.org ♦ Web www.tahd.org

*"Promoting Health & Preventing Disease Since 1967"*

Borough of Bantam  
Bethlehem  
Canaan  
Cornwall  
Goshen  
Harwinton  
Kent  
Borough of Litchfield  
Litchfield  
Middlebury  
Morris  
Norfolk  
North Canaan  
Plymouth  
Salisbury  
Thomaston  
Torrington  
Warren  
Watertown  
Winsted

86 Workman Ave  
Torrington, CT 06790

## **XRF Lead Testing Performed by Robert Rubbo; MPH, R.S.**

### **Calibration Checks**

#1 = 1.0      #4 = -0.3  
#2 = 1.0      #5 = -0.2  
#3 = 1.0      #6 = -0.2

### **Living Room**

Wall A = 0.1  
Baseboard Wall C = 0.1  
Wall D window Sill = 0.1  
Wall D window jamb = 0.1  
Front Door jamb = 1.0 (defective)

### **Kitchen**

Wall B = -0.4  
Window well wall D = 1.4 (defective)

### **Child's Bedroom**

Closet door jamb = -0.2  
Window sash wall C = -0.1  
Baseboard wall C = 9.9 (defective)  
Closet door frame = 9.9 (defective)  
Wall B = -0.3

### **Master Bedroom**

Window jamb wall B = 9.9 (defective)  
Ceiling above drop ceiling = 6.1 (defective)  
Master bedroom baseboard wall D = 2.6 (defective)

### **Common area on side B**

Wall B common stairway = 0.3  
Door casing = 8.8 (defective)  
Door to outside = -0.1

### **Front Porch**

Window sill = 9.3 (defective)  
Exposed exterior wall by railing = 9.9 (defective)

### **Calibration Checks**

#1 = 1.0      #4 = -0.2  
#2 = 1.0      #5 = -0.2  
#3 = 0.7      #6 = -0.2

The Torrington Area Health District is an equal opportunity provider, and employer.

To file a complaint of discrimination write USDA, Director, Office of Civil Rights, 1400 Independence Avenue, S.W., Washington, D.C., 20250-9410, or call (800) 795-3272 (voice), or (202) 720-6382 (TDD).

86 WORKMANS AVE  
Torrington, CT  
8/11/15  
1ST FLOOR

